

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

**Professional
Laboratory
Services**

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 06/19/2014

Received: 06/12/2014

Sampled By: CE Latour

Work Order: 4163013

C L I E N T **PBS Engineering & Environmental**

Attn: Connie Latour

1500 D St

Vancouver WA, 98663

Phone: (360) 213-0449

Project: HSD DW 2014

Project # : 23440.003

PWSID # : 4190606

Sampling Location: Farmington View


Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 6/12/14 9:55		Sample Composition: Distribution				
4163013-01	Health Room, Sink							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	0.798	0.050	1.3	-	06/13/14 13:00
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	06/18/14 15:23

Lab Number	Sample Name	Sampled: 6/12/14 10:00		Sample Composition: Distribution				
4163013-02	South, Girl's R.R., Sink							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	0.535	0.050	1.3	-	06/13/14 13:00
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	06/18/14 15:23

Lab Number	Sample Name	Sampled: 6/12/14 10:05		Sample Composition: Distribution				
4163013-03	Classroom 10, Sink							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	ND	0.050	1.3	-	06/13/14 13:00
†Lead	1030	EPA 200.9	mg/L	0.006	0.002	0.015	-	06/18/14 15:23

Lab Number	Sample Name	Sampled: 6/12/14 10:10		Sample Composition: Distribution				
4163013-04	Classroom 3, Sink							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	ND	0.050	1.3	-	06/13/14 13:00
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	06/18/14 15:23



13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

**Professional
Laboratory
Services**

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 06/19/2014

Received: 06/12/2014

Sampled By: CE Latour

Work Order: 4163013

C L I E N T **PBS Engineering & Environmental**

Attn: Connie Latour
1500 D St
Vancouver WA, 98663
Phone: (360) 213-0449

Project: HSD DW 2014

Project # : 23440.003

PWSID # : 4190606

Sampling Location: **Farmington View**

Sample Matrix: Drinking Water

Lab Number
4163013-05

Sample Name
Kitchen Sink

Sampled: 6/12/14 10:20

Sample Composition: Distribution

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	0.306	0.050	1.3	-	06/13/14 13:00
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	06/18/14 15:23

ND = None detected

MRL = Minimum Reporting Limit


MCL = Maximum Contamination Limit

†All procedures for this analysis conform to NELAC standards.

Approved by:

Scott Dickman
Lab Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.



13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

**Professional
Laboratory
Services**

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 06/19/2014
Received: 06/12/2014
Sampled By: CE Latour
Work Order: 4163014

C L I E N T **PBS Engineering & Environmental**

Attn: Connie Latour
1500 D St
Vancouver WA, 98663
Phone: (360) 213-0449

Project: HSD DW 2014

Project # : 23440.003

PWSID # : 4193774


Sampling Location: **West Union Ele.**
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 6/12/14 9:05		Sample Composition: Distribution				
4163014-01	South, Girl's Restroom Sink							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	ND	0.050	1.3	-	06/13/14 13:00
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	06/18/14 15:23

Lab Number	Sample Name	Sampled: 6/12/14 9:10		Sample Composition: Distribution				
4163014-02	South, Boy's Restroom Sink							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	ND	0.050	1.3	-	06/13/14 13:00
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	06/18/14 15:23

Lab Number	Sample Name	Sampled: 6/12/14 9:15		Sample Composition: Distribution				
4163014-03	Classroom 18, Sink							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	ND	0.050	1.3	-	06/13/14 13:00
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	06/18/14 15:23

Lab Number	Sample Name	Sampled: 6/12/14 9:20		Sample Composition: Distribution				
4163014-04	Kitchen, Sink							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	ND	0.050	1.3	-	06/13/14 13:00
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	06/18/14 15:23



13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

**Professional
Laboratory
Services**

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 06/19/2014

Received: 06/12/2014

Sampled By: CE Latour

Work Order: 4163014

C L I E N T **PBS Engineering & Environmental**

Attn: Connie Latour
1500 D St
Vancouver WA, 98663
Phone: (360) 213-0449

Project: HSD DW 2014

Project # : 23440.003

PWSID # : 4193774

Sampling Location: **West Union Ele.**
Sample Matrix: Drinking Water

Lab Number
4163014-05

Sample Name
Classroom 4, Sink

Sampled: 6/12/14 9:25

Sample Composition: Distribution

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	ND	0.050	1.3	-	06/13/14 13:00
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	06/18/14 15:23

ND = None detected

MRL = Minimum Reporting Limit


MCL = Maximum Contamination Limit

†All procedures for this analysis conform to NELAC standards.

Approved by:

Scott Dickman
Lab Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.



13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

**Professional
Laboratory
Services**

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 06/19/2014
Received: 06/12/2014
Sampled By: CE Latour
Work Order: 4163012

C L I E N T
PBS Engineering & Environmental
Attn: Connie Latour
1500 D St
Vancouver WA, 98663
Phone: (360) 213-0449

Project: HSD DW 2014
Project # : 23440.003
PWSID # : 4190607


Sampling Location: Groner Ele
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 6/12/14 10:30			Sample Composition: Distribution			
4163012-01	Health Room, Sink							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	0.524	0.050	1.3	-	06/13/14 13:00
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	06/18/14 15:23

Lab Number	Sample Name	Sampled: 6/12/14 10:35			Sample Composition: Distribution			
4163012-02	Kitchen, Sink							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	0.058	0.050	1.3	-	06/13/14 13:00
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	06/18/14 15:23

Lab Number	Sample Name	Sampled: 6/12/14 10:40			Sample Composition: Distribution			
4163012-03	Classroom 13, Sink							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	ND	0.050	1.3	-	06/13/14 13:00
†Lead	1030	EPA 200.9	mg/L	0.003	0.002	0.015	-	06/18/14 15:23

Lab Number	Sample Name	Sampled: 6/12/14 10:45			Sample Composition: Distribution			
4163012-04	Faculty Rest Room, Sink							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	0.050	0.050	1.3	-	06/13/14 13:00
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	06/18/14 15:23



13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

**Professional
Laboratory
Services**

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 06/19/2014

Received: 06/12/2014

Sampled By: CE Latour

Work Order: 4163012

C **PBS Engineering & Environmental**
L Attn: Connie Latour
I 1500 D St
E Vancouver WA, 98663
N Phone: (360) 213-0449
T

Project: HSD DW 2014

Project # : 23440.003

PWSID # : 4190607

Sampling Location: Groner Ele
Sample Matrix: Drinking Water

Lab Number
4163012-05

Sample Name
Classroom 3, Sink

Sampled: 6/12/14 10:50

Sample Composition: Distribution

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	0.182	0.050	1.3	-	06/13/14 13:00
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	06/18/14 15:23

ND = None detected

MRL = Minimum Reporting Limit

MCL = Maximum Contamination Limit

†All procedures for this analysis conform to NELAC standards.

Approved by: _____

Scott Dickman
Lab Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.